



Fire Department Event Vendor Requirements

Food Truck or Trailer

Separated at least 10 ft. away from any other equipment or trucks

Annual Fire Department Inspection

Hood extinguishing system serviced in last 6 months

Hood cleaning performed by independent service company in last 6 months with current cleaning sticker

Any of the fire extinguishers below have been serviced and tagged in last 12 months:

Fire extinguisher sized 2A10BC

Fire extinguisher sized K 1.5 gal for every 80 lbs. cooking oil or 6 sq ft.

Fire extinguisher sized K 1.5 gal. for every 5-cu. ft. fire box in solid fuel cooking

Combustible gas alarm plugged in and operational

Fuel line system tested within last 12 months and proof of record gas pressure tests needs to be on site.

Cooking Tents

Separated by at least 20 ft. from any other tent

Any of the below required fire extinguishers serviced and tagged in last 12 months:

Fire extinguisher sized 2A10BC

Fire extinguisher sized K 1.5 gal. for every 80 lbs. cooking oil capacity or 6 sq. ft.

Fire extinguisher sized K 1.5 gal. for every 5-cu. ft. fire box in solid fuel cooking

Cooking not under tent

Separated 20 ft. from any tent, and 10 ft. from any combustibles

Any of the below required fire extinguishers serviced and tagged in last 12 months:

Fire extinguisher sized 2A10BC

Fire extinguisher sized K 1.5 gal. for every 80 lbs. cooking oil capacity or 6 sq. ft.

Fire extinguisher sized K 1.5 gal. for every 5-cu. ft. fire box in solid fuel cooking

Generators

Separated 10 ft. from any combustibles, and 20 ft. from any tent

Located at least 5 ft. from any opening door or window

Isolated from public by 3 ft. enclosure

Fire extinguisher sized 2A20BC serviced and tagged within last 12 months

Prohibited Items During Events

No portable heaters electric or fuel fired

No flammable liquids or combustible gases containers left out in public view (generators or fuel fired appliances may have 1 tank connected and topped off prior to event starting, during event any extra fuel must be removed from event space.)