



Fire Protection Systems Work and Submittals

FIRE DEPARTMENT

2406 Leopard
Suite 300
Corpus Christi
Texas 78408
Phone 361-826-3900
Fax 361-887-8053
www.cctexas.com

*Seeking
Opportunities
to Serve*

Scope of Work Letters

1. FACP replacements (document UL listing compatible and updated dialer if still using landline)
2. Monitoring devices replacements
3. Alarm system adding or deleting devices up to 2
4. Sprinkler system adding up to 10 heads
5. Sprinkler system relocating and adding total up to 20 heads
6. Special extinguishing system any changes in appliances type, location, or the cooking type of food or material.

Plan Submittals

1. New alarm system
2. Full alarm system replacement
3. New sprinkler system
4. Sprinkler system adding more than 10 heads
5. Sprinkler system relocating and adding more than 20 heads
6. Extinguishing system in Type 1 Hood - not pre-engineered and incorporated into the design from the manufacturer.
7. Special suppression system any new install.

Resubmittals

1. Alarm system more than 2 devices added or deleted from approved plans
2. Sprinkler system adding more than 10 heads to an already approved plan
3. Fire line any changes in approved plans (size, layout, turns, etc.)

As built plans

1. Will be required if any deviations in the approved plans that do not require any resubmittals must be received prior to acceptance

